



ADDENDUM #1

RFP 20-008

**2020 LMIG Street Paving**

This addendum is being issued to address questions submitted on RFP 20-008.

1. The City of Commerce will be responsible for adjustments of any sewer manholes, water valves, and grates.
2. The City will be responsible for patching, and the contractor will be responsible for leveling to DOT standards.
3. The overlay topping shall be asphalt 1.5" F Mix of GDOT 9.5mm Type II (165#SY)
4. This project requires no milling to be done. The asphalt shall be feathered into the gutter of the curb.
5. The contractor shall provide estimated materials needed in tons of mix and gallons of tack.
6. There is no set allowable time for lane closures as long as they are clearly posted in advanced. Most of the streets are small secondary roads in residential areas. So please use best judgement.
7. The listed quantities is in Linear Feet and the streets average 18-20 feet wide.
8. The attached Bid Form on Appendix A shall be used individually for each street listed in the project.

This addendum should be signed and returned with your proposal.

James Elrod  
Accounting Manager  
City of Commerce

Company Name \_\_\_\_\_

Authorized Representative \_\_\_\_\_